

Depth of Water Penetration Under Pressure

Report No: UXB0382377/755/M3 **Report Date:** 9 January 2018
Our Contract Ref: 51035549

Client: BASEMENT EXPERT LTD
Address: 5 Greenway
Walkern
Stevenage
Herts
SG2 7NR
Date Cast: 10 Jul 2017
Date Sampled: Not given
Date Received: 7 Aug 2017
Date Tested: 7 Aug 2017 -

Client Contact: Coppard Concrete Services
Site: Court Farm, Crowborough
Location: Basement Floor Slab
Tested By: SOCOTEC Uxbridge

Mix Details: P350 CEM1 S1 O/S & Powerful Plasticiser
Sampling Certificate: Not Received
Sample Type: Water
Sampled by: Client

Results:

Laboratory Reference:	24620755
Client Ref:	C4
Width / Diameter (mm):	150
Condition Upon Receipt:	Satisfactory
Direction of water pressure relative to casting direction:	Vertical
Age of Test (Days):	28
Depth of Penetration (mm):	7

Certified that the test was determined in accordance with BSEN 12390-8:2009

Signed:



Clive Moore - QA Management
for and on behalf of SOCOTEC UK Limited